

# APPROVAL FOR CONSTRUCTION

THE PLANS AND SPECIFICATIONS FOR SEWAGE  
OR WASTE DISPOSAL SYSTEM SUBMITTED FOR:

APPROVAL # 116654

Owner:

Margaret O'Donoghue  
536 Manchester Street  
Seabrook, NH 03874

LOT NUMBERS: 536  
SUBD. APPVL.#:  
SUBD. NAME: exist. lot Seabrook Beach

Copy of Plan & Approval sent to:

Board of Selectmen  
Town Office  
Seabrook, NH 03874

TYPE OF SYSTEM: Duplex = 300 GPD  
FAILED SYSTEM

TOWN/CITY LOCATION: Seabrook, NH  
STREET LOCATION: Manchester St.

By Applicant: PERMIT # 348

Anne W. Bialobrzewski  
247 Landing Road  
Hampton, NH 03842

PLEASE POST IN A CONSPICUOUS PLACE  
DURING CONSTRUCTION.

THIS APPROVAL DOES NOT SUPERCEDE  
ANY EQUIVALENT OR MORE STRINGENT  
LOCAL ORDINANCES OR REGULATIONS.  
STATE STANDARDS ARE MINIMAL  
AND MUST BE MET STATEWIDE.

WHITE= Applicant's; YELLOW= Town's; BLUE= NHWS&PCC file; GOLD= Owner's - (No Action Required)

NOTE: ( XX ) Gravity system ( ) Gravity system to septic tank and effluent pump chamber  
with disposal system to be constructed on a properly prepared base.

Bed bottom to be set: ( ) no deeper than \_\_\_\_\_" below the original grade  
( ) no less than \_\_\_\_\_" above the original grade  
( ) no lower than the original grade

to maintain ( XX ) 2' minimum above (the reported) (xxx) seasonal high water table.  
( XX ) 8' minimum above (the reported) (xxx) ledge depth. WAIVER APPROVED.  
( ) \_\_\_\_\_' minimum above (the reported) (any) impermeable soil.

( ) Fill to prepare disposal area should be a medium to coarse sand (0.5 to 1.0 mm).  
( ) This approval only valid for the above owner's domicile/exemption.

are approved this date: Nov. 7, 1984

William E. Evans

By: William E. Evans  
vcg N.H. Water Supply & Pollution Control  
Commission Staff (OVER)

Revised 8/1/80

## PERC TEST

DATE: \_\_\_\_\_

DEPTH OF HOLE: \_\_\_\_\_

RATE OF PERC: < 1 MIN/IN

EXISTING LOADING: DUPLEX CURRENTLY 3 PERSONS  
(SEASONAL INCREASES)

AREA OF OLD FAILED SYSTEM: 12 ± SQ. FT.

AREA OF NEW SYSTEM: 10x40 FOR  
400 SQ. FT. AREA PROVIDED

### REVIEWED AND APPROVED

IN ACCORDANCE WITH THE  
REQUIREMENTS OF THE

NEW HAMPSHIRE  
WATER SUPPLY & POLLUTION  
CONTROL COMMISSION

Signed

Date

William E. Evans  
11-7-84  
116654

PLAN OF PROPOSED

SEPTIC SYSTEM


REPLACING FAILED SYSTEM

LOCUS: 536 MANCHESTER ST  
SEABROOK, NH

APPLICANT

OWNER: MARGARET O'DONOGHUE  
536 MANCHESTER ST  
SEABROOK, NH 03874

APPLICANT: ANNE W. BIALOBRZESKI  
247 LANDING ROAD  
HAMPTON, N.H. 03842  
DESIGNER PERMIT #348



DATE: 10/20/84 REV 11/2/84

APPROVAL: \_\_\_\_\_

21